

Waterworks Characteristics

Municipality	Treatment Capacity (GPD)	Average Demand (GPD)	Peak Demand (GPD)	Storage Capacity (Gal)	Source
Cambridge	875000	212000	340000	385000	Wells
Colona	1250000	360000	580000	887000	Wells
Galva	1350000	380000	550000	452000	Wells
Geneseo	2300000	750000	1200000	1200000	Wells
Kewanee	3600000	1750000	2000000	1500000	Wells
Orion	468000	165000	210000	310000	Wells

Source: Individual Municipalities and Iowa American Water Company, 2006

Wastewater Treatment

Municipality	Design Capacity (GPD)	Average Load (GPD)	Peak Load (GPD)	Type of Treatment
Cambridge	880000	343000	1592000	Primary
Colona	1000000	400000	750000	Primary & Secondary
Galva	1500000	500000	3000000	Primary & Secondary
Geneseo	4500000	800000	4500000	Primary & Secondary
Kewanee	5000000	2500000	7000000	Secondary
Orion	400000	500000	1000000	Tertiary

Source: Individual Municipalities, 2006